WHEREAS, by letter dated April 21, 1980, the Supply System did request a turbidity waiver in relation to construction of access roads and a culvert crossing of Elizabeth Creek on the Flink Farm property in accordance with Sections III.D.3 and III.D.6 of the Site Certification Agreement for WPPSS Nuclear Projects 3 and 5; and

WHEREAS, the Council recognizes that short term increases in turbidity may result from access road construction and culvert installation;

NOW, THEREFORE, BE IT RESOLVED by the Energy Facility Site Evaluation Council that it grants a temporary waiver of the water quality standards subject to the following conditions:

- 1. Construction activity in Elizabeth Creek must be confined to the period June 1 to September 15 unless otherwise approved by the Council.
- 2. Construction of the access roads and culvert crossing of Elizabeth Creek shall be in accordance with Drawing WPPSS-3240-G-2121, Revision 2.
- 3. No discharge of visible oil or grease shall be permitted to reach any receiving water.
- 4. The water quality criteria set forth in WAC 173.201.030 (2)(c)(VI) as for turbidity is hereby modified for the period begining 0100 hours, May 1,1980 and terminating 2400 hours, September 15, 1980 in accordance with the following conditions:
 - A. Sampling at the mouth of Elizabeth Creek will be done twice daily during culvert installation. Analyses will be for turbidity and settleable solids. There will be no effluent limitations during culvert installation.
 - B. Access road construction, excluding culvert installation, shall cease when the effluent exceeds a daily average of 75 NTU with no more than a three hour period in excess of 300 NTU or when settleable solids exceed 0.1 ml/l.
 - C. In the event that the contractor or subcontractor is unable to meet the above requirements, or when construction activities will result in water quality degradation below the standards specified in Paragraph B, the Council will be notified immediately.

Dated this 28th day of April, 1980.

WASHINGTON STATE ENERGY FACILITY SITE EVALUATION COUNCIL

Nicholas D. Lewis

Chairman

ATTEST:

William L. Fatch Executive Secretary

APPROVED AS TO FORM:

Kevin M. Ryan

Assistant Attorney General