

RESOLUTION NO. 177

*Closed out by
Resolution #217-9/23/83*

WHEREAS, By letter of March 7, 1980, the Washington Public Power Supply System did request, in accordance with Section III.D.6 of the Site Certification Agreement for WPPSS Nuclear Projects 3 and 5, a turbidity waiver in relation to the proposed bank stabilization in the area of the intake well fields; and,

WHEREAS, By letter of April 30, 1980, the Supply System submitted revised plans in relation to the proposed bank stabilization; and,

WHEREAS, The Council recognizes that short term increases in turbidity may result during construction of the bank stabilization;

NOW, THEREFORE, BE IT RESOLVED By the Energy Facility Site Evaluation Council that it grants a temporary waiver of the water quality standards subject to the following conditions:

1. Sedimentation and erosion control facilities for the proposed bank stabilization shall be as shown in the following referenced documents:

Ebasco Services Inc., Contract 3240-254

Ebasco Services Inc., Specification 3240-446

Drawing Nos. WPPSS-3240-G-2121 Rev. 2, and
more particularly

WPPSS-3240-G-2130-S1 Rev. 2

WPPSS-3240-G-2130-S2 Rev. 2

2. Construction activity in the Chehalis River main stem and Elizabeth Creek must be confined to the period June 1 to September 15 unless otherwise specifically approved by the Council.
3. Spoil materials from the stream bank caused by sloping or dressing activity in preparation for mat placement shall be spread in such a manner as to minimize adverse effects on the passage of flood flows and/or re-entry into the Chehalis River.
4. No discharge of visible oil or grease will be permitted to reach any receiving water.
5. The water quality criteria set forth in WAC 173.201.030 - (2)(c)(vi) as for turbidity is hereby modified for the period beginning 0100 hours, June 1, 1980 and terminating 2400 hours, September 15, 1980, in accordance with the following conditions:

Sampling of the Chehalis River upstream and downstream of the construction area will be done daily during construction activity. Sampling results will be reported to the Council monthly. Analyses will be for turbidity and settleable solids.

6. The State of Washington acting by and through the Council does certify that there is no applicable standard under 33 U.S.C. 1311, 1312, 1316 and 1317. The State does certify that any discharges to navigable waters which may result from construction of WNP 3 and 5 so long as done in accordance with this resolution or subsequent resolutions and the Site Certification Agreement executed on October 27, 1976, will comply with applicable state law and the limitations identified herein.

DATED This 12th day of May 1980.

WASHINGTON STATE ENERGY FACILITY
SITE EVALUATION COUNCIL


By



Nicholas D. Lewis
Chairman

ATTEST:

By



William L. Fitch
Executive Secretary

APPROVED AS TO FORM:

By



Kevin M. Ryan
Assistant Attorney General