

**STATE OF WASHINGTON
ENERGY FACILITY SITE EVALUATION COUNCIL (EFSEC)**



**TECHNICAL SUPPORT DOCUMENT
AND
STATEMENT OF BASIS**

GRAYS HARBOR ENERGY CENTER, LLC

<Date final>

PERMIT #:	EFSEC/25-01-AOP
PREPARED FOR:	Grays Harbor Energy, LLC 401 Keys Road Elma, WA 98541-9149
PLANT SITE:	Grays Harbor Energy Center 401 Keys Road Elma, WA 98541-9149
PERMIT ENGINEER:	Aaron Manley – ORCAA Professional Engineer
REVIEWED BY:	Sonia E. Bumpus – EFSEC Executive Director

**ENERGY FACILITY SITE EVALUATION COUNCIL
621 Woodland Square Loop
P.O. Box 47250
Lacey, Washington 98503-3172
Telephone: (360) 664-1345**

TABLE OF CONTENTS

1.	DISCLAIMER.....	1
2.	GENERAL INFORMATION	1
2.1	Table 1: Administrative Information and Contact Information.....	1
2.2	Facility Description.....	2
2.3	Basis for Title V Applicability	2
2.4	Preconstruction Permitting	2
	Table 2: AGP - CGT Changes.....	3
	Table 3: AGP – Facility Changes	3
2.5	Regulatory History	4
2.6	Table 4: Permitting History	4
2.7	Compliance History	6
2.8	Effective Versions of Applicable Requirements	6
	Table 5: Landmark Dates for Federal Regulation.....	6
	Table 6: Landmark Dates for State Regulations.....	7
	Table 7: Effective Dates for PSD and NSR Permits.....	8
2.9	AOP Enforcement.....	8
2.10	AOP Enforcement Contractor	9
2.11	Owner and Operator	9
2.12	GHEC Responsible Official	9
3.	FACILITY DESCRIPTION	10
3.1	General Overview.....	10
3.2	Fuel.....	11
3.3	Combined Cycle Gas Turbines (CGT1 & CGT2)	11
3.4	Steam Turbine	15
3.5	Auxiliary Boiler.....	16
3.6	Cooling Tower	16
3.7	Emergency Generator.....	18
3.8	Diesel-fired Water Pump Engine (Fire Water Pump Engine).....	18
3.9	Table 8: Summary of Emissions Units	19
3.10	Insignificant Emissions Units (IEUs)	20
3.11	Table 9: Insignificant Emissions Units (IEUs)	20
4.	Emissions	21
4.1	Table 10: Criteria Pollutant Potential to Emit (PTE).....	21

4.2	Table 11: 2017 Actual Emissions	21
4.3	Table 12: HAP Potential to Emit (PTE)	22
5.	Regulatory Determinations	22
	Table 13 Applicability Determinations.....	22
6.	Basis for AOP Terms and Conditions.....	28
6.1	Table 14: EFSEC Rules Adopted by Reference	28
6.2	Table 15: Required Permit Content, Washington AOP Program.....	29
6.3	Permit Administration (P1 – P21).....	30
6.4	General Terms and Conditions (G1 – G16).....	32
6.5	Applicable Requirements.....	35
6.6	Monitoring and Recordkeeping Conditions	37
6.7	General Recordkeeping Requirements.....	38
6.8	Reporting	38
6.9	Permit Shield	38
7.	Environmental Justice	38
7.1	Identify Overburdened Communities	39
7.2	Engage with Communities	39
7.3	Evaluate Cumulative Impacts.....	40
7.4	Use Available Authority to Minimize Emissions	40

1. DISCLAIMER

Information contained in this Technical Support Document is for purposes of background information only and is not enforceable. Applicable requirements including emission limits and monitoring, recordkeeping and reporting requirements are contained in the associated Air Operating Permit (AOP) for the Grays Harbor Energy Center, permit EFSEC/25-01-AOP, which was issued by the Energy Facility Site Evaluation Council (EFSEC) on <Date final>.

2. GENERAL INFORMATION

2.1 Table 1: Administrative Information and Contact Information

Company Name	Grays Harbor Energy, LLC (GHEC)
Facility/Source Name	Grays Harbor Energy Center (GHEC)
AOP Permit No.	EFSEC/25-01-AOP
Mailing Address	Grays Harbor Energy, LLC 401 Keys Road Elma, WA 98541-9149
Site Address	Grays Harbor Energy, LLC 401 Keys Road Elma, WA 98541-9149
Facility/Plant/Environmental Manager	Eric Pace Plant Engineer (360) 482-6292
Responsible Official	Chris Sherin Plant Manager
Unified Business Identification Number	602 082 646
Standard Industrial Classification (SIC) Code	4911
Attainment Area Status	Unclassified for all criteria pollutants.
Permitting Authority	The Washington Energy Facility Site Evaluation Council (EFSEC) is the permitting authority for the GHEC. EFSEC implements an Air Operating Permit program through Chapter 463-78 WAC, which adopts by reference the Washington Operating Permits Regulations under Chapter 173-401 WAC.
Enforcement Manager	Sara Randolph – EFSEC Energy Facility Site Specialist (360) 485-1594
Compliance Contractor	Olympic Region Clean Air Agency (ORCAA) (360) 539-7610
Permit Engineer	Aaron Manley – ORCAA Engineer II (360) 539-7610 ext 104
Compliance Manager	Mike Shults – Compliance Manager (360) 539-7610 ext 113

2.2 Facility Description

Grays Harbor Energy, LLC (GHE) owns and operates an electricity generation facility located at 401 Keys Road in Elma, Grays Harbor County, Washington. The facility is referred to as the Grays Harbor Energy Center (GHEC). GHEC is capable of generating up to 662.4 megawatts (MW, @ 59° F) of electricity from a combined-cycle power plant comprised of two combustion turbines, each equipped with a duct burner and heat recovery steam generator and a single steam turbine and bank of cooling towers shared in common. GHEC also operates an auxiliary boiler, a diesel emergency generator, and an emergency fire water pump. Commercial operation of GHEC began on April 25, 2008.

2.3 Basis for Title V Applicability

Facilities with a potential to emit (PTE) at or above the “major source” thresholds defined in WAC 173-401-200(19) are required to operate under an Air Operating Permit (AOP) issued through an approved Washington State AOP program, according to Title V of the Federal Clean Air Act (FCAA). GHEC has the potential to emit several regulated air pollutants above their major source thresholds. In addition, GHEC is an affected source under Title IV (Acid Deposition Control) of the FCAA, which independently triggers the requirement to obtain a Title V AOP.

EFSEC received delegation from EPA Region 10 on August 13, 2001, to implement an AOP program for electric power generating plants in Washington State with capacities exceeding 350 MW. EFSEC implements their AOP program through Chapter 463-78 WAC, which adopts by reference the Washington Operating Permits Regulations under Chapter 173-401 WAC.

Because GHEC is capable of generating up to 662 MW of electricity and is a “major source” as defined in WAC 173-401-200(19), GHEC is required to operate under an AOP issued by EFSEC.

2.4 Preconstruction Permitting

EFSEC is responsible for issuing pre-construction permits to electric power generating plants in Washington with capacities exceeding 350 MW, including Notice of Construction (NOC) permits and Prevention of Significant Deterioration (PSD) permits. Both types of permits have been issued to GHEC by EFSEC.

EFSEC issued the initial PSD approval to the previous owner of the facility (Duke Energy) in 2001 and approved transfer of the PSD permit to GHE in April 2005. The PSD permit for GHEC has been amended five separate times since it was originally issued in 2001. The following list summarizes the PSD permitting history of the facility:

1. Original PSD Approval (EFSEC/2001-01, approved November 2, 2001) – Includes both PSD and minor NOC permits to construct the GHEC;
2. Amendment 1 (EFSEC/2001-01 Amendment 1, January 2, 2003) - Approved modified operating requirements and emission limitations, added equipment as part of the project and removed certain operational restrictions;
3. Amendment 2 (EFSEC/2001-01 Amendment 2, October 19, 2004) - Approved a delay in continuous construction to no later than January 20, 2006, and modified the

monitoring requirements and BACT emission limitations based on recently available information;

4. Amendment 3 (EFSEC/2001-01 Amendment 3, approved April 3, 2006) - Approved a second delay in continuous construction to no later than July 20, 2007, and made several administrative corrections;
5. Amendment 4 (EFSEC/2001-01 Amendment 4, approved June 28, 2018) corrected certain minor errors in the permit and adopted specific emissions limits for startup and shutdown operations; and
6. Amendment 5 (EFSEC/2001-01 Amendment 5, approved January 28, 2021) approved upgrades referred to as Advanced Gas Path (AGP) upgrades. These were upgrades to the two General Electric (GE) combustion turbines at the facility to enable more efficient operation. The AGP upgrades enabled more efficient operation at increased firing temperatures while maintaining compliant emissions levels. The AGP upgrades resulted in the following changes at the facility:

Table 2: AGP - CGT Changes

	CGT01		CGT02	
	MMBtu/hr	MW	MMBtu/hr	MW
Pre-AGP @ 59°F	1,671	175	1,671	175
Pre-AGP Design	NA	175	NA	175
Historical Max (unadjusted for temperature)	1,835	187	1,835	188
Post-AGP @ 59°F	1,823	181.2	1,823	181.2
Post-AGP projected, historical max	0.994	0.969	0.994	0.964

Table 3: AGP – Facility Changes

Max Heat Rates, MMBtu/hr			
	Pre-AGP	Post-AGP	
Ambient Temp.	At 59°F	At 59°F	At 14°F
Turbine	1735	1823	2,011
Duct Burner	505	505	505
Total	2240	2328	2,516

Max Output Rates, MW			
Combustion Turbine	175	181.2	206
Steam Turbine	300	300	300
Total	650	662.4	718
Lb CO2/MW	820	822	822

2.5 Regulatory History

The regulatory history of GHEC is fairly complicated due to:

1. Delays in starting and completing construction of the facility; and,
2. Delays in securing approval of Amendment 4 by Region 10 of the U.S. Environmental Protection Agency (EPA).

Start of construction and construction delays necessitated the need for permit extensions. In addition, construction delays triggered the need to re-permit the facility because effective versions of applicable regulations, which depend on when an affected facility begins construction, required re-evaluation.

PSD Amendment 5, which was issued by EFSEC on January 28, 2021, is the effective pre-construction air permit for GHEC. Table 4 summarizes the permitting history for GHEC.

2.6 Table 4: Permitting History

1995	Construction Authorized - EFSEC authorizes construction and operation
1996	Original PSD Approval - Site Certification Agreement (SCA) with PSD (EFSEC 95-01)
March 1998	Permit extension
September 1999	Permit extension
April 2001	Re-Application - Duke submitted a new PSD application for project
June 2001	EPA Consent Order - Administrative Order on Consent issued by EPA allowing start of construction prior to issuance of the new PSD approval.
September 1, 2001	Start of Construction – authorized by EFSEC
November 2, 2001	PSD Approval - (EFSEC/2001-01)
January 2, 2003	PSD Amendment 1 (EFSEC/2001-01 Amendment 1) - EFSEC approves Amendment 1, which modified operating requirements and emission limitations in the original approval, added equipment as part of the project and

	removed certain operational restrictions.
October 19, 2004	PSD Amendment 2 (EFSEC/2001-01 Amendment 2) - approved by EFSEC authorizing a delay in continuous construction to not later than January 20, 2006, and modifying the monitoring requirements and BACT emission limitations based on recently available information. Amendment 2 did not change or add any emission units that were either proposed for installation or already installed at the facility.
February 23, 2005	Transfer of Ownership - to Grays Harbor Energy LLC approved by EFSEC.
April 3, 2006	Amendment 3 (EFSEC/2001-01 Amendment 3) - approved by EFSEC authorizing a second delay in continuous construction to not later than July 20, 2007, and making several administrative corrections to errors in Amendment 2.
April 25, 2008	Start of Commercial Operation.
April 24, 2009	Date Complete Title V Application Submitted
August 7, 2009	Application for PSD Amendment 4 was submitted to EFSEC
September 29, 2018	Amendment 4 (EFSEC/2001-01 Amendment 4) - requested by GHE in 2009 to: <ul style="list-style-type: none"> 1. Rectify issues with the PSD permit identified during development of the Air Operating Permit for the facility; 2. Add specific startup/shutdown emissions limits; and, 3. Rectify permit issued raised by EPA.
June 17, 2020	EFSEC/94-1 AOP-Initial issued by EFSEC
January 28, 2021	Amendment 5 (EFSEC/2001-01 Amendment 5, approved January 28, 2021) approved upgrades referred to as Advanced Gas Path (AGP) upgrades.
July 17, 2024	EFSEC/94-1 AOP – 1 st Modification, - issued by EFSEC
October 6, 2025	Draft AOP - issued for public comment
<Date>	Proposed AOP – submitted to EPA for review
<Date>	Final AOP - issued by EFSEC

2.7 Compliance History

The EFSEC has issued one Notice of Violation to GHEC, which occurred on March 9, 2012. Based on testing of emissions from turbine 2 on September 4, 2011, GHEC violated EFSEC 2001-01 Amendment 3 Condition 5.6.2, which states emission of particulate matter from the turbines must not exceed 0.003 grains per dry standard cubic foot (gr/dscf), including filterable and condensable particulate, and corrected to 15% oxygen. Testing on September 4, 2011, showed particulate emissions slightly above the limit. GHEC investigated and concluded the excess particulate was an anomaly and possibly a result of rust from the stack lining. The Notice of Violation was resolved when GHEC tested on March 15, 2012, confirming compliance with the standard. Results from this test documented particulate emissions at 0.0003 gr/dscf, which meets the standard.

2.8 Effective Versions of Applicable Requirements

Conditions in this AOP originate from state, federal, and EFSEC regulations and standards and are generally referred to as “applicable requirements.” AOP conditions reflect the versions of each applicable requirement in effect at the time the AOP modification application was submitted. Certain applicable requirements may have had multiple versions in effect at the time the AOP modification application was submitted due to either:

1. An amendment to the associated regulation/rule/standard that occurred after EFSEC adopted the regulation by reference; or,
2. An older version of the rule/regulation/or standard adopted by EFSEC in their State Implementation Plan (SIP).

In these instances, both versions of the applicable requirement apply and are reflected in the AOP condition.

The following tables clarify the “landmark” dates that establish the effective versions for each applicable requirement contained in the AOP. However, any disputes regarding the exact language of an applicable requirement covered in the AOP should be settled by consulting versions of the associated rules/regulations/standards based on the “landmark dates” shown in the following tables.

Table 5: Landmark Dates for Federal Regulation

Federal Regulations	Date Federal Regulation Adopted by EFSEC^a	EFSEC Delegation Date^b
40 CFR 60, Subpart A (§ 60.1 to § 60.19 except § 60.5 and § 60.6)	11/11/2019	Not Delegated
40 CFR 51, Subpart K	11/11/2019	Not Delegated
40 CFR 52, Subpart A	11/11/2019	Not Delegated
40 CFR 60, Subpart IIII	11/11/2019	Not Delegated
40 CFR 60, Subpart KKKK	11/11/2019	Not Delegated
40 CFR 60, Appendices	11/11/2019	Not Delegated
40 CFR 61, Subpart A	11/11/2019	Not Delegated
40 CFR 61, Subpart M	11/11/2019	Not Delegated
40 CFR 63, Subpart A	11/11/2019	Not Delegated

40 CFR 63, Subpart ZZZZ	11/11/2019	Not Delegated
40 CFR 63, Appendices	11/11/2019	Not Delegated
40 CFR 72	11/11/2019	Not Delegated
40 CFR 75	11/11/2019	Not Delegated
40 CFR 75, Appendices	11/11/2019	Not Delegated
40 CFR 82, Subpart B	11/11/2019	Not Delegated
40 CFR 82 Subpart F	11/11/2019	Not Delegated

- a. The “Date Federal regulation Adopted by EFSEC” is set by the date established in WAC 463-78-005(1), which is the effective date of EFSECs adoption by reference for all federal and state regulations adopted by EFSEC. At the time EFSEC submitted their AOP renewal application, WAC 463-78-005(1) stated November 11, 2019, as the effected date for adoption by reference. Therefore, the versions of federal regulations cited in this permit are those that existed on 11/11/2019.
- b. The “EFSEC Delegation Date” is the date EFSEC was granted delegation to enforce the specific federal regulation. EFSEC has not yet received federal rule delegation from EPA.

Table 6: Landmark Dates for State Regulations

State Regulations	SIP Regulation Version Effective Date^a	Date State Regulation Adopted by EFSEC^{b, c}
WAC 173-400-036	12/29/2012	11/11/2019
WAC 173-400-040(2)(a & b) - Visible Emissions	4/1/2011	11/11/2019
WAC 173-400-040(3) – Fallout	Not in SIP	11/11/2019
WAC 173-400-040(4)- Fugitive Emissions	9/16/2018	11/11/2019
WAC 173-400-040(5) - Odors	Not in SIP	11/11/2019
WAC 173-400-040(6) - Detrimental Emissions	9/16/2018	11/11/2019
WAC 173-400-040(7) - SO2 Emissions	9/16/2018	11/11/2019
WAC 173-400-040(8) - Concealment and Masking	9/16/2018	11/11/2019
WAC 173-400-040(9) - Fugitive Dust	9/16/2018	11/11/2019
WAC 173-400-050 (Except: 173-400-050(2), (4), (5), and (6).	9/16/2018	11/11/2019
WAC 173-400-060	9/16/2018	11/11/2019
WAC 173-400-105	11/25/2018	11/11/2019
WAC 173-400-108	Not in SIP	Not Adopted Effective version of rule is 12/11/2024
WAC 173-400-109	Not in SIP	Not Adopted Effective version of rule is 12/11/2024

WAC 173-400-110	12/29/2012	11/11/2019
WAC 173-400-114	Not in SIP	11/11/2019
WAC 173-400-230	Not in SIP	Not Adopted Effective version of rule is 12/11/2024
WAC 173-400-700	4/1/2011	11/11/2019
WAC 173-401	Not in SIP	11/11/2019
WAC 173-406	Not in SIP	11/11/2019
WAC 173-425	10/18/1990	11/11/2019
WAC 173-441	Not in SIP	11/11/2019
WAC 173-460	Not in SIP	11/11/2019
WAC 463-78-105 (Fees)	Not in SIP	EFSEC Rule No adoption required (Effective 8/27/2015)
WAC 463-78-115	Not in SIP	EFSEC Rule No adoption required (Effective 8/27/2015)
WAC 463-78-120 (Testing)	11/11/2004	11/11/2004

- a. The “SIP Regulation Version Effective Date” is the effective date of the specific regulation listed in EFSEC’s State Implementation Plan.
- b. The “State Regulation Version Adoption Date” is set by the date established in WAC 463-78-005(1), which is the effective date of EFSECs adoption by reference for all federal and state regulations adopted by EFSEC. At the time GHEC submitted their AOP renewal application, WAC 463-78-005(1) stated November 11, 2019, as the effected date for adoption by reference. Therefore, the versions of federal regulations cited in this permit are those that existed on 11/11/2019.
- c. For those State regulations not adopted by EFSEC, the date the AOP renewal application was submitted sets the date of the effective version of the regulation.

Table 7: Effective Dates for PSD and NSR Permits

Regulatory Orders/Permits	Effective Dates
Acid Rain Permit No. <ACID RAIN #>	<date acid rain permit issued>
PSD No. EFSEC/2001-01, AMENDMENT 5	1/28/2021
No. EFSEC NOC 17-01 (Cooling Tower Replacement)	4/18/2017

2.9 AOP Enforcement

Terms and conditions in the AOP apply continuously and are enforceable by EFSEC. Each condition in the AOP cites both the regulatory origin and authority for each permit condition. Any disputes regarding the exact language of an applicable requirement listed in GHEC’s AOP should be settled by consulting the regulation cited in the regulatory origin of the condition.

2.10 AOP Enforcement Contractor

Through a Memorandum of Agreement (MOA) signed by EFSEC on November 20, 2007, Olympic Region Clean Air Agency (ORCAA) was given the contract to serve as the air compliance /permitting contractor under EFSEC. Through this agreement, ORCAA is tasked with performing all air-related compliance monitoring and Title V permitting duties for GHEC on behalf of EFSEC. Under EFSEC's oversight and direction, ORCAA performs such tasks as annual inspections, source testing oversight, review of monitoring reports, responding to complaints, drafting the AOP and reporting findings to EFSEC. While ORCAA serves as the compliance/permitting contractor, EFSEC remains the regulatory authority over GHEC. This means that ORCAA reports findings directly to EFSEC who then may act on the findings at their discretion. Only EFSEC can issue Notices of Violation (NOVs) and penalties for non-compliance.

2.11 Owner and Operator

GHEC is the current owner and operator of the GHEC and is the entity responsible for complying with the AOP. Ownership of the facility was transferred from the former owners, Duke Energy and Energy Northwest to GHEC on February 23, 2005. GHEC, a subsidiary of Invenergy, is a private company categorized under Electric Power Generation, and is located in Elma, WA. The parent company, Invenergy, and its affiliates develop, own and operate large-scale renewable and other clean energy generation facilities in North America and Europe. Invenergy specializes in developing and operating clean power sources of energy such as combined cycle power plants that operate using natural gas.

2.12 GHEC Responsible Official

AOP regulations under Chapter 173-401 WAC require a "Responsible Official" certify any submittals regarding compliance with the AOP as being true, accurate and complete based on their belief formed after reasonable inquiry. To form a reasonable belief of the truth, accuracy, and completeness of a compliance certification or other AOP-related submittal, the Responsible Official needs to understand the significance of the submittal with respect to assuring compliance with the AOP. The Responsible Official must have a basic understanding of the Title V permitting program, an understanding of the deviations being reported, how permit deviations are determined and the role of credible evidence in certifying compliance.

AOP compliance-related submittals cover practically every report and submittal associated with an AOP, such as deviation reports, malfunction reports, periodic monitoring reports, test reports, quarterly reports and annual compliance certifications. The AOP as written for GHEC does allow for "batch-wise" certification of routine compliance reports. This is facilitated by condition P21, which states:

"Provided, however, where a report is sent more frequently than once every six months, the responsible official's certification need only be submitted once every six months, covering all required reporting since the date of the last certification."

This allows the Responsible Official to batch-wise certify retroactively all reports submitted since the last certification.

According to WAC 173-401-200(29), the responsible official means one of the following:

- a) For a corporation: A president, secretary, treasurer, or vice president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit and either:
 - (i) The facilities employ more than two hundred fifty persons or have gross annual sales or expenditures exceeding forty-three million in 1992 dollars; or
 - (ii) The delegation of authority to such representative is approved in advance by the permitting authority;
- b) For a partnership or sole proprietorship: A general partner or the proprietor, respectively;
- c) For a municipality, state, federal, or other public agency: Either a principal executive officer or ranking elected official. For the purposes of this part, a principal executive officer of a federal agency includes the chief executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., a regional administrator of EPA); or
- d) For affected sources:
 - (i) The designated representative in so far as actions, standards, requirements, or prohibitions under Title IV of the FCAA or the regulations promulgated thereunder and in effect on April 7, 1993 are concerned; and
 - (ii) The designated representative for any other purposes under 40 C.F.R. Part 70.

Because GHEC is subject to an acid rain permit under Title IV of the FCAA, the definitions under “d” apply. Therefore, for GHEC, the Responsible Official and “Designative Representative” for the Acid Rain Permit should be the same person.

3. FACILITY DESCRIPTION

3.1 General Overview

GHEC is an electricity production facility occupying approximately 20 acres within the Satsop Redevelopment Park in Grays Harbor County, which is approximately four miles southwest of Elma, Washington. The facility consists of a combined-cycle electric power generating plant including two General Electric natural gas-fired combustion turbine generators (GE 7FA), operated in a “2-x-1” combined cycle gas turbine configuration with one steam turbine (GE D11) shared in common. The steam turbine is part of a steam power cycle that generates additional electric power from the waste heat in the exhaust of the combustion turbines. Each turbine is followed by a duct burner and a heat recovery steam generator (HRSG) to generate the steam used by the steam turbine. The steam turbine itself is not a direct source of air emissions, but requires operation of duct burners, heat recovery steam generators (HRSGs) and a cooling tower. The duct burners and the cooling towers are

sources of air emissions themselves. GHEC also includes an auxiliary natural gas fired boiler, a diesel-fired emergency generator and a diesel-fired water pump.

3.2 Fuel

All combustion equipment except the diesel-fired emergency generator and diesel-fired water pump are fueled by natural gas received from the Williams Co.'s., Northwest Pipeline. The natural gas is sampled monthly by GHEC and analyzed to determine its sulfur and heat content.

The diesel fuel allowed for use in the emergency generator and fire water pump engines is non-road specification diesel fuel with a maximum sulfur content of 15 ppm.

3.3 Combined Cycle Gas Turbines (CGT1 & CGT2)

Description

The combustion turbine generators are identical GE 7FA units and are each rated at maximum power generating capacity of 181.2 MW @ 59°F. Each combustion turbine has a design maximum heat-rate of 1,823 million British thermal units per hour (MMBtu/hr). Each combustion turbine is equipped with a heat recovery steam generator (HRSG) which has a duct burner. Each duct burner has a design maximum heat-rate of 505 MMBtu/hr.

In this Technical Support Document and the associated AOP, each combustion turbine, duct burner and HRSG combination is referred to as a "Combined-Cycle Gas Turbine Unit" or CGT unit. Each CGT unit has a separate exhaust stack. The western-most CGT is designated as CGT1 and the eastern-most CGT is designated as CGT2.

The combustion turbines take in filtered air that is compressed in the compressor stage of the turbine and then mixed with natural gas. The compressed fuel and air mixture is then burned in the combustion chamber of the turbine where it is expanded through a series of turbines to convert the energy to mechanical rotating shaft power. This mechanical energy is then used to run the compressor section of the turbine and to directly power the electric generator.

High temperature exhaust produced by each combustion turbine is augmented with supplemental heat from its duct burner to generate high pressure steam in its connected HRSG. Each HRSG produces steam that is used by the steam turbine to generate power in a standard steam power cycle.

Each CGT exhausts through its own exhaust stack at a height of 180 feet above ground level. Exhaust stacks are each equipped with a caged ladder and stack testing platform that provide a permanent and safe access to stack testing ports. The testing ports conform to the requirements of 40 CFR, Part 60, Appendix A, Method 20.

Air emissions from the CGTs result from combustion of natural gas both in the combustion turbines and duct burners. Natural gas is the only fuel combusted. Air pollutant emissions from the CGTs include nitrogen oxides (NO_x), carbon monoxide (CO), particulate matter with an aerodynamic diameter equal to or less than ten micrometers (PM₁₀), sulfur dioxide (SO₂),

volatile organic compounds (VOCs), sulfuric acid mist (H_2SO_4), ammonia (NH_3) and several Hazardous Air Pollutants (HAPs). Actual as well as potential emissions rates are described in section 4 of this TSD below.

CGT NO_x Control and Monitoring

The combustion turbines incorporate “Advanced, Dry Low NO_x ” combustor technology. This technology is guaranteed by the manufacturer to reduce NO_x emissions from the combustion turbines to 9 ppm. It accomplishes NO_x reduction by maintaining a “lean” premix of fuel to air, staging the combustion into three-stages and utilizing a central diffusion flame for overall flame stabilization. The lean, premixed technology burns a lean fuel-to-air mixture for a lower peak combustion flame temperature, which results in lower “thermal NO_x ” formation. The combustion turbines operate with just one of the lean premixed stages and the diffusion pilot at lower loads, and additional stages at higher loads. This provides efficient combustion and lower temperatures throughout the combustor-loading regime.

The duct burners also incorporate low NO_x combustor technology. This burner technology is capable of maintaining NO_x emissions below 10 ppmvd at 15% oxygen.

The typical NO_x emission concentration from each CGT is in the 3 to 9 ppm range. NO_x from each CGT is further treated by separate selective catalytic reduction (SCR) units downstream of each HRSG. The SCR units are capable of maintaining NO_x concentrations to less than 2.0 ppm at 15% oxygen during steady state operation of the CGTs.

SCR is a post-combustion NO_x control technology where ammonia (NH_3) is injected into the flue gas upstream of a vanadium oxide catalytic reactor. The catalyst bed operates most efficiently at temperatures between 600 and 800°F, which match the temperature range typically found within HRSG units. On the catalyst surface, the NH_3 reacts with NO_x to form molecular nitrogen and water. The process uses approximately 1 – 1.3 moles of NH_3 per mole of NO_x reduced. The rate of NH_3 injection is automatically controlled based on the amount of “ NH_3 slip,” which is the concentration of unreacted NH_3 downstream of the SCR units. NH_3 slip is continuously monitored.

The primary variable affecting SCR performance is temperature. If operating below the optimum temperature range, the catalyst activity is reduced, allowing unreacted NH_3 to slip through into the exhaust stream. If operating above the optimum temperature range, NH_3 is oxidized, forming additional NO_x . In addition, the catalyst may suffer thermal stress damage. Temperature of the catalyst beds as well as NO_x concentrations are required to be continuously monitored in order to maintain NO_x rates below the permitted limits.

An aqueous solution of NH_3 is used as the source for NH_3 in order to minimize impacts of possible spills or the unlikely event of rupture of an NH_3 tank. The solution is approximately 19% NH_3 as received and used. The rate of NH_3 solution injection is automatically regulated based on the NH_3 slip rate, which is continuously monitored. NH_3 slip is limited to 5 ppm on a 24-hour average basis. The NH_3 pump is controlled to maintain NH_3 slip between 1 and 3 ppm.

Per the PSD permit, NO_x emission concentrations and rates from the CGTs are required to be continuously monitored. As such, both CGTs are equipped with continuous emissions monitoring systems (CEMS) for NO_x and O_2 , which is referred to as a NO_x -diluent CEMS. The

NO_x-diluent CEMS is subject to the requirements contained in 40 CFR Part 75, Continuous Emission Monitoring, which contains the continuous emissions monitoring requirements for facilities subject to the Acid Rain program. Because 40 CFR Part 75 establishes the monitoring requirements for all pollutants and parameters required to be monitored under the acid Rain program (NO_x, O₂, SO₂, CO₂, volumetric flow, and opacity), and for different types of combustion units, much of it is not applicable to GHEC. For this reason, 40 CFR Part 75 is incorporated by reference in the permit.

On a real-time basis, GHEC can verify compliance with any of the short-term NO_x limits from the NO_x-diluent CEMS. In addition, the NO_x-diluent CEMS triggers an alarm to notify the operator when concentrations approach any short-term limit. NO_x concentrations measured by the NO_x-diluent CEMS is used to determine the NO_x concentrations in terms of parts per million by volume at 15%O₂, which is the metric of the CGT emissions concentration limits. For pollutant mass rate (PMR) limits, measured NO_x concentrations are coupled with the natural gas combustion rate measured by the fuel monitoring system and a Fuel Factor (Fd) measured monthly to calculate the NO_x PMR in terms of pounds per hour.

The natural gas combustion rate is monitored continuously by separate fuel flow meters on each CGT and Duct Burner (DB) in terms of cubic feet per hour. Cubic feet per hour of natural gas combusted by each unit is multiplied by the Fd (measured monthly) to compute the exhaust gas flowrate for each unit in terms of dry standard cubic feet per hour at 15% O₂. This result is then multiplied by the concentration to compute the NO_x PMR as shown in the following equation.

$$PMR_x = (NG)(HHV)(Fd)(Cx)(MW_{pollutant}) / [(1000)(Molar Volume_{stp})]$$

Where:

- *PMR_x = The calculated pollutant mass rate of pollutant “x” in terms of pound per hour (lbs/hr).*
- *NG = The actual amount of natural gas combusted by the unit over the hour per condition M6(a) in terms of dry standard cubic feet of natural gas (dscfng/hr).*
- *HHV = The Higher Heat Value of the natural gas determined for the month per condition M6(b)(i) in terms of million Btu per dry standard cubic feet of natural gas (MMBtu/dscfng).*
- *Fd = The dry basis fuel factor determined for the month per condition M6(b)(ii) in terms of dry standard cubic feet of exhaust per million Btu of natural gas combusted (dscf_{exhaust}/MMBtu)*
- *Cx = The average concentration of pollutant “x” monitored by CEMS over the hour in terms of parts per million by volume, dry (ppmvd), uncorrected.*

-Although the detailed equations for PMRs were removed from the AOP, this equation is maintained in the TSD intentionally as a reference point.

CGT CO Control and Monitoring

The dry low NO_x combustors in the CGTs also minimize the formation of CO. Minimizing NO_x is usually at the expense of higher CO emissions, however, the “Advanced, Dry Low

NO_x combustor technology is able to optimize the combustors to minimize emissions of both pollutants. The dry low NO_x combustors are expected to maintain a CO emission rate well below 9 ppm. In addition to CO control through the dry low NO_x combustors, exhaust from each CGT passes through a platinum catalyst (following the SCR units) where oxygen in the gas stream reacts with CO to produce CO₂. The CO oxidation catalyst technology is capable of reducing CO concentration by 90+%.

Per the PSD permit, CO emission concentrations and rates from the CGTs are required to be continuously monitored. The CO CEMS must meet the requirements contained in 40 CFR Part 60, Appendix B: Performance Specification 4 or 4a, and in 40 CFR, Part 60, Appendix F: Quality Assurance Procedures. CO CEMS requirements are incorporated by reference in the permit.

From the CO CEMS data, GHEC can verify compliance with both short-term and long-term average limits. In addition, the CEMS triggers an alarm when CO concentrations approach any of the short CO limits. This is done automatically by the CO data acquisition system (DAS).

CGT SO₂, H₂SO₄ and PM₁₀ Control and Monitoring

Combusting only natural gas is the principle means for minimizing emissions of particulate matter, sulfur dioxide and sulfuric acid from each CGT. Per the PSD permit, continuous monitoring of the rate of natural gas combustion by each turbine and DB is required. In addition, natural gas is required to be sampled monthly and analyzed to determine sulfur and heat content.

For SO₂ and H₂SO₄, the PSD permit imposes only PMR limits. Monitoring compliance is accomplished by calculating emissions rate using sulfur balance calculations based on the actual amount and composition of natural gas combusted and emissions factors from stack testing relating the percentage of H₂SO₄ to SO₂. The amount of natural gas combusted is continuously monitored by gas flow meters on each turbine and DB. Meters measure the gas flow rate and automatically correct to standard temperature and pressure units based on the monitored pipeline gas temperature and pressure. This data is periodically cross-checked by GHEC against fuel certifications provided by the Williams Pipeline Company.

Per the PSD permit, gas flow meters are required to be installed, operated, and maintained according to 40 CFR Part 75, Appendix D. Also, natural gas heat and sulfur content are required to be determined monthly through direct sampling and analyzing the natural gas per 40 CFR Part 75, Appendix D. 40 CFR Part 75, Appendix D is incorporated by reference in the permit.

PM₁₀ emissions from the CGTs are each limited to no more than 22.6 lb/hr of filterable plus condensable PM₁₀. The required monitoring means is to calculate PM₁₀ emissions based on the actual amount of natural gas combusted during each 24-hr period time an emissions factor based on the most recent particulate stack testing.

Reference method testing is the required means for monitoring compliance with the particulate grain loading limit. For the first three years of operation testing was required annually. Provided testing verifies compliance, the required testing frequency is relaxed to once every 5-years. Stack testing results must be reported as total particulate, filterable particulate and condensable particulate.

CGT Ammonia Emissions Monitoring

Per the PSD permit, NH₃ emissions (NH₃ slip) from each CGT is required to be continuously monitored. NH₃ CEMSs must meet the requirements contained in 40 CFR, Part 63, Appendix A, Reference Method 301, Validation Protocol (Validation Protocol), and 40 CFR, Part 60, Appendix F, Quality Assurance Procedures (Appendix F), or other EFSEC-approved performance specifications and quality assurance procedures. Because neither the Validation Protocol nor Appendix F contain actual performance specifications for operating NH₃ CEMSs, performance specifications needed to be adopted into the AOP to fill this void. Washington's Title V regulations under WAC 173-401-615(1)(b) allow adopting monitoring requirements into a Title V AOP when requirements are not adequately specified. This approach to adding monitoring to a Title V AOP is referred to as "gap-filling monitoring".

Until NH₃ CEMS performance specifications are adopted as final by EPA, EPA's Preliminary Performance Specification for Ammonia Continuous Emission Monitors (PPS-001, EPA, 2005) can serve as a surrogate performance specification. PPS-001 has not yet been published in the Federal Register but is proposed by EPA as their preferred performance specifications for NH₃ CEMS. PPS-001 establishes specifications for the allowable range, calibration drift and accuracy for NH₃ CEMS. The PPS-001 performance specifications are then inserted into the Validation Protocol for initial testing of NH₃ CEMS and Appendix F for ongoing quality assurance and control of NH₃ monitors.

CGT Opacity Monitoring

Per the PSD permit, opacity of the exhaust from each CGT must be monitored. Two options are provided for opacity monitoring:

- A certified opacity reader can read and record the opacity of each operating unit during daylight hours daily and then weekly if compliance is maintained for the previous calendar month; or,
- Opacity can be monitored using a Continuous Opacity Monitoring System (COMS) on each CGT as an alternative.

Per the PSD permit, COMS must meet the requirements contained in 40 CFR Part 60, Appendix B, Performance Specification 1 and in 40 CFR, Part 60, Appendix F, Quality Assurance Procedures. Both are incorporated by reference in the permit.

3.4 Steam Turbine

Description

The GE D11 steam turbine generates electricity using steam produced by the Heat Recovery Steam Generators (HRSGs). Each HRSG produces superheated steam using leftover heat energy from its associated gas turbine plus supplemented heat energy from its associated DB. The steam turbine itself is not an emissions unit but is an integral part of the combined cycle power plant. The steam turbine power cycle requires operation of the CGTs (turbines + DBs), Cooling Tower and Auxiliary Boiler during startup. The steam turbine generator can produce up to an additional 300 MW of electric power. The steam power cycle is a closed loop process where exhaust steam from the steam turbine is condensed by passing through the cooling towers and then pumped as liquid water back to the HRSGs in a continuous

closed-loop arrangement. Since the steam turbine has no direct air pollutant emissions, it is not designated as an emissions unit.

3.5 Auxiliary Boiler

Description

Start-up of the combined cycle power plant requires an auxiliary heat source to provide heat while the CGTs are warming up. This is accomplished by a separate, 29.3 MMBtu/hr natural gas-fired Auxiliary Boiler. The Auxiliary Boiler is used primarily to assist with start-up of the CTG units. The Auxiliary Boiler also provides initial steam for the steam turbine during startup.

Auxiliary Boiler Emissions Control and Monitoring

The Auxiliary Boiler employs low NO_x burners, good combustion practices, and the use of natural gas for controlling air pollutant emissions.

The PSD permit establishes hourly and annual emissions limits for the Auxiliary Boiler for NO_x, CO, SO₂, VOC, PM₁₀, and opacity. The PSD permit does not require CEMS for the Auxiliary Boiler but does require periodic stack testing to demonstrate compliance with permit limits. The PSD permit also requires monthly calculations of emissions over the previous 12-consecutive month period to monitor compliance with annual emissions limits to verify compliance with annual emissions limits. The prescribed calculation method for all pollutants except SO₂ requires using actual natural gas consumption data and emissions factors based on the most recent stack testing results. For SO₂, emissions must be based on fuel sulfur monitoring data and sulfur balance calculations. For opacity, certified opacity readings are required once per month.

3.6 Cooling Tower

Description

As mentioned previously, the steam power cycle is a closed-loop process whereby steam remaining after expanding through the steam turbine is condensed so the entire flowrate of the “working fluid” can be pumped back to the HRSGs in order to complete the steam power cycle. Pumping produces high pressures in the working fluid loop, which is needed by the steam turbine to generate power. The Cooling Tower enables the closed loop steam power cycle by expelling waste heat through one, nine-cell, forced draft cooling unit. The Cooling Tower transfers heat to the ambient air through evaporation of water. Water used by the Cooling Tower is pumped from a well located nearby on the Chehalis River.

GHEC maintains Cooling Tower water quality to prevent high concentrations of chemicals and dissolved solids that would lead to particulate emissions and odors. Cooling Tower water is continuously monitored for pH, free chlorine, oxidation reduction potential (ORP) and conductivity to assure water quality. Sodium Hypochlorite (bleach) is added to prevent biological growth in the Cooling Tower. The sodium hypochlorite is added automatically to maintain 0.2 – 0.6 ppm free chlorine. Sulfuric acid (H₂SO₄) to prevent scaling is added

automatically to maintain pH between 8.1 and 8.5. The bleach, H₂SO₄ and bromine are all added to the water via constant volume pumps that are automatically controlled based on continuous monitoring of the water quality.

Design operating specifications for GHEC's Cooling Tower are as follows:

- 1,535,200 cubic feet per minute (ft³/min) air flow at design conditions (9 fans total)
- 175,000 gallons per minute (gpm) recirculating water flow
- 1,165 milligrams per liter (mg/L) total dissolved solids
- Addition of 93% H₂SO₄ (sulfuric acid) to water at a variable rate, but approximately 70 gallons per day (gpd) average when the plant is running.
- Addition of 12.5% NaClO (sodium hypochlorite) to water at a variable rate, but approximately 104 gal/day average when the plant is running.
- 2H Drift Eliminators manufactured by ENEXIO with a drift rate less than 0.0005 percent.

Cooling Tower Monitoring

The Cooling Tower emits PM₁₀ in the form of particulate suspended or dissolved in tiny airborne water droplets, which are referred to as "drift." VOCs and chlorine compounds may also be emitted in drift if Cooling Tower water quality is not maintained. The GHEC Cooling Tower is equipped with "drift eliminators" to reduce drift and air emissions associated with the drift. GHEC's Cooling Tower employs drift eliminators rated at a drift loss rate of less than 0.0005% of the recirculating cooling water flow rate.

The permit requires monthly calculation of the daily (annual average) and annual cooling tower PM₁₀ emissions rates based on design flow rates for the circulating water pumps, circulating water pump operating records, conductivity, conductivity to total dissolved solids (TDS) correlation factor, and a drift loss rate of 0.000005 gallons per gallon of recirculating water. The level of TDS in the cooling tower water determines the potential for PM₁₀ emissions as dissolved solids precipitate to particulate as the cooling tower water evaporates using the following formula:

$$\frac{Q \times C \times 0.000005 \times 60 \times 8.34}{1000000} = D$$

Where:

Q = Either the actual or design recirculating water flow rate in gallons per minute

C = total dissolved solids concentration in parts per million by weight (ppmw)

D = particulate emission rate in lb/hr.

0.000005 = the drift loss rate in gallon lost/gallon of recirculating cooling water

TDS is monitored indirectly by monitoring conductivity of the cooling tower water (TDS is directly related to conductivity). The level of TDS is controlled by adjusting the rate of make-up water to the cooling tower to maintain conductivity below 1,200 micro-ohms

conductivity. Conductivity is monitored continuously, and an alarm is triggered in the control room when conductivity reaches 1,200 micro-ohms to alert operators to manually adjust the make-up water rate.

3.7 Emergency Generator

Description

GHEC relies on one 400 kilowatt (536 horsepower) Caterpillar, model 3456, diesel-fired emergency generator (Emergency Generator) to provide electricity during power outages. This is critical for GHEC to power down equipment and maintain operation of lubricating oil pumps during power outages. The manufacture date of the Emergency Engine was 2002.

Engine Make & Model	Caterpillar, model 3456
Engine Serial #	CER00348
Date engine was ordered	7/22/2002
Model year of engine	2002
Engine BHP	536 BHP
Engine KW	400 KW

40 CFR Part 60, Subpart IIII (Subpart IIII) does not apply to the Emergency Generator at GHEC because the order date of the Emergency Generator precedes the effective date of Subpart IIII. 40 CFR Part 63, Subpart ZZZZ (Subpart ZZZZ) does apply. In addition to Subpart ZZZZ, the Emergency Generator is subject to requirements from PSD Amendment 5.

Emergency Generator Monitoring

The permit requires monitoring sufficient to verify the Emergency Generator engine is operated, maintained, and repaired in a manner consistent with the manufacturer's emissions-related specifications. In addition, total hours of operation and hours of maintenance testing must be tracked and recorded.

3.8 Diesel-fired Water Pump Engine (Fire Water Pump Engine)

Description

The facility includes a 205 kilowatt (275 horsepower) Fire Water Pump Engine for fire suppression during electrical power outages.

Engine Make & Model	John Deere, model No. 6081AF001
Engine Serial #	RG6081A146553
Date engine was ordered	Pre 2002
Model year of engine	2001
Engine BHP	275 BHP
Engine KW	205 KW

40 CFR Part 60, Subpart IIII (Subpart IIII) does not apply to the Fire Water Pump Engine at GHEC because the order date of the Fire Water Pump Engine precedes the effective date of

Subpart IIII. 40 CFR Part 63, Subpart ZZZZ (Subpart ZZZZ) does apply. In addition to Subpart ZZZZ, the Fire Water Pump Engine is subject to requirements from PSD Amendment 5.

Fire Water Pump Engine Emissions Control and Monitoring

The permit requires monitoring sufficient to verify the Fire Water Pump Engine is operated, maintained and repaired in a manner consistent with the manufacturer's emissions-related specifications. In addition, total hours of operation and hours of maintenance testing must be tracked and recorded.

3.9 Table 8: Summary of Emissions Units

ID	Description	Control Devices	Permit #s
EU-1	Combined Cycle Gas Turbine 1 (CGT1): <ul style="list-style-type: none"> Combustion Turbine 1 (CT1) – General Electric 7FA natural gas turbine with a nominal design heat rate of 1,823 mmBtu/hr and an output of 234 KVA. Duct Burner 1 (DB1) – 505 mmBtu/hr natural gas duct burner 	<ul style="list-style-type: none"> CT1 equipped with Dry-Low NO_x Combustors DB1 equipped with Low NO_x Burners. Exhaust from both CT1 and DB1 pass through Selective Catalytic Reduction (SCR) and CO catalyst systems 	EFSEC/2001-01 Amendment 5
EU-2	Combined Cycle Gas Turbine 2 (CGT2): <ul style="list-style-type: none"> Combustion turbine – General Electric 7FA natural gas turbine with a nominal design heat rate of 1,823 mmBtu/hr and an output of 234 KVA. Duct Burner – 505 mmBtu/hr natural gas duct burner 	<ul style="list-style-type: none"> CT2 equipped with Dry-Low NO_x Combustors DB2 equipped with Low NO_x Burners. Exhaust from both CT2 and DB2 pass through Selective Catalytic Reduction (SCR) and CO catalyst systems 	
EU-3	Auxiliary Boiler: 29.3 mmBtu/hr natural gas fired boiler used to assist with start-up.	<ul style="list-style-type: none"> Low NO_x burners Flue Gas Recirculation (FGR) 	
EU-4	Cooling Tower: Nine cell, 175,000 gal/min forced draft cooling tower	<ul style="list-style-type: none"> Equipped with drift eliminators 	
EU-5	Emergency Generator: 400 kW (536 hp) emergency generator used to help power down equipment and maintain operation of lubricating oil pumps in the event of power outages.	None	
EU-6	Emergency Fire Water Pump: 205 kW (275 bhp) diesel-fired water pump to provide for fire suppression during electrical power outages.	None	

3.10 Insignificant Emissions Units (IEUs)

The equipment listed in Table 9 was identified by GHEC as insignificant emissions units (IEUs) as defined under WAC 173-401-200(17). IEUs are exempt from Title V permit program requirements as provided under WAC 173-401-530. None of the IEUs listed in Table 9 are a significant source of emissions or subject to equipment-specific air quality requirements. Because all of the IEUs listed in Table 9 are “categorically exempt” IEUs, they are not required to be listed in the GHEC AOP.

Testing, monitoring, recordkeeping and reporting required by the AOP are not required for IEUs unless determined by the permitting authority to be necessary to assure compliance, or unless it is otherwise required by a generally applicable requirement of the state implementation plan.

Where a permit does not require testing, monitoring, recordkeeping and reporting for an IEU, the Permittee may certify continuous compliance if there were no observed, documented, or known instances of noncompliance during the reporting period. Where a permit does require testing, monitoring, recordkeeping and reporting for an IEU, the Permittee may certify continuous compliance when the testing, monitoring, recordkeeping required by the permit revealed no violations during the period, and there were no observed, documented, or known instances of noncompliance during the reporting period. The permit shield per WAC 173-401-640 does not apply to IEUs.

3.11 Table 9: Insignificant Emissions Units (IEUs)

ID	Description	Size/Capacity	IEU Basis
IEU	Mobile Fugitive Emissions	Na	WAC 173-401-530(1)(d)
IEU	Lubricating Oil Tank	Na	WAC 173-401-532(3)
IEU	Hydraulic Oil Tank	Na	WAC 173-401-532(4)
IEU	Storage of Pressurized Gases	Na	WAC 173-401-532(5)
IEU	Maintenance Shops	Na	WAC 173-401-532(7)
IEU	Continuous Emissions Monitoring Systems (CEMs)	Na	WAC 173-401-532(7)
IEU	Vents	Na	WAC 173-401-532(9)
IEU	Vehicle Internal Combustion Engines	Na	WAC 173-401-532(10)
IEU	Welding Operations	Na	WAC 173-401-532(12)
IEU	Plant Upkeep Activities	Na	WAC 173-401-532(33)
IEU	Pavement Cleaning and Sweeping	Na	WAC 173-401-532(35)
IEU	Food Preparation	Na	WAC 173-401-532(41)
IEU	Portable Drums and Totes	Na	WAC 173-401-532(42)
IEU	Lawn and Landscaping Activities	Na	WAC 173-401-532(43)
IEU	General Vehicle Maintenance	Na	WAC 173-401-532(45)
IEU	Comfort Air Conditioning	Na	WAC 173-401-532(46)
IEU	Office Activities	Na	WAC 173-401-532(49)
IEU	Sampling Connections	Na	WAC 173-401-532(51)
IEU	Parking Lot Exhaust	Na	WAC 173-401-532(54)
IEU	Indoor Activities	Na	WAC 173-401-532(55)

ID	Description	Size/Capacity	IEU Basis
IEU	Repair and Maintenance	Na	WAC 173-401-532(74)
IEU	Air Compressors	Na	WAC 173-401-532(88)
IEU	Steam Leaks	Na	WAC 173-401-532(89)
IEU	Vacuum System Exhaust	Na	WAC 173-401-532(108)

4. Emissions

GHEC's emissions of criteria air pollutants and ammonia are characterized in the following tables. Table 10 shows cumulative, facility-wide emissions in terms of maximum potential to emit (PTE). PTE values represent maximum permitted emissions from all emissions units at GHEC based on enforceable emissions limits and maximum operating rates for all regulated emissions units. Table 11 shows actual emissions for calendar year 2023. Actual emissions are based on monitored fuel consumption rates, measured natural gas heat and sulfur content, and monitored emissions concentrations over calendar year 2023. Table 12 shows cumulative, facility-wide HAP emissions in terms of maximum potential to emit (PTE).

4.1 Table 10: Criteria Pollutant Potential to Emit (PTE)

Pollutant	Potential to Emit (tons)	Source of Data
CO (Carbon Monoxide)	144	AOP Permit Application
PM 2.5 (Fine Particulate (<= 2.5 microns))	203	AOP Permit Application
PM-10 (Fine Particulate (<=10 microns))	203	AOP Permit Application
NO _x (Nitrogen Oxides)	245	AOP Permit Application
VOC as Volatile Organic Compounds	92	AOP Permit Application
SO ₂ (Sulfur Dioxide)	29	AOP Permit Application
H ₂ SO ₄ (sulfuric acid)	19	AOP Permit Application
NH ₃ (ammonia)	141	AOP Permit Application

4.2 Table 11: 2023 Actual Emissions

Pollutant	2023 Emissions (tons)	Source of Data
CO (Carbon Monoxide)	10.9	ORCAA 2023 Inventory
PM 2.5 (Fine Particulate: <= 2.5 microns)	40.3	ORCAA 2023 Inventory
PM-10 (Fine Particulate:<=10 microns)	40.3	ORCAA 2023 Inventory
NO _x (Nitrogen Oxides)	90.1	ORCAA 2023 Inventory
VOC as Volatile Organic Compounds	8.0	ORCAA 2023 Inventory
SO ₂ (Sulfur Dioxide)	10.3	ORCAA 2023 Inventory
H ₂ SO ₄ (sulfuric acid)	0.5	ORCAA 2023 Inventory
NH ₃ (ammonia)	18.1	ORCAA 2023 Inventory

4.3 Table 12: HAP Potential to Emit (PTE)

Pollutant	Potential to Emit (tons)	Source of Data
Acedaldehyde	0.64	AOP Permit Application
Acrolein	0.0102	AOP Permit Application
Arsenic	0.00087	AOP Permit Application
Benzene	0.20	AOP Permit Application
Beryllium	5.20E-5	AOP Permit Application
1,3-Butadiene	0.0069	AOP Permit Application
Cadmium	0.0048	AOP Permit Application
Chromium, trivalent	0.0030	AOP Permit Application
Chromium, hexavalent	0.0030	AOP Permit Application
Cobalt	0.00036	AOP Permit Application
Ethylbenzene	0.51	AOP Permit Application
Formaldehyde	1.75	AOP Permit Application
Hexane	7.81	AOP Permit Application
Manganese	0.0016	AOP Permit Application
Mercury	0.0011	AOP Permit Application
Naphthalene	0.023	AOP Permit Application
Nickel	0.0091	AOP Permit Application
Poly Aromatic Hydrocarbons	0.035	AOP Permit Application
Propylene Oxide	0.46	AOP Permit Application
Selenium	0.00010	AOP Permit Application
Toluene	2.09	AOP Permit Application
Xylenes	1.02	AOP Permit Application
Total HAP	14.67	AOP Permit Application

5. Regulatory Determinations

Table 13 summarizes regulatory determinations made for GHEC's AOP.

Table 13 Applicability Determinations

Citation	Description	Applicable Requirement under Title V?	Basis
40 CFR Part 60 Subpart GG	Stationary Gas Turbine NSPS	No	According to the Washington Department of Ecology (Ecology), as documented in the Fact Sheet for PSD Amendment 5, GHEC's AGPupgrades triggered applicability of the combustion turbine standards in 40 CFR Part 60, Subpart KKKK (Subpart KKKK). Under § 60.4305 of Subpart KKKK it states, "Stationary combustion turbines

Citation	Description	Applicable Requirement under Title V?	Basis
			regulated under this subpart are exempt from the requirements of subpart GG of this part.” Therefore, the requirements under Subpart GG do not apply to the combustion turbines at GHEC. It also states, “Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.”
40 CFR Part 60 Subpart Da	Electric Utility Steam-Generation Units	No	According to Ecology, as documented in the Fact Sheet for PSD Amendment 5, GHEC’s AGP upgrades triggered applicability of the combustion turbine standards in 40 CFR Part 60, Subpart KKKK . Under § 60.4305 of Subpart KKKK it states, “Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.”
40 CFR Part 60 Subpart Db	Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units	No	
40 CFR Part 60 Subpart Dc	Small Institutional-Commercial-Industrial Steam Generation Units	No – for heat recovery steam generators and duct burners Yes – Auxiliary boiler	
40 CFR Part 60 Subpart KKKK	Subpart KKKK - Standards of Performance for Stationary Combustion Turbines	Yes	According to Ecology, as documented in the Fact Sheet for PSD Amendment 5, GHEC’s AGP upgrades triggered applicability of the combustion turbine standards in 40 CFR Part 60, Subpart KKKK . Subpart imposes standards for NO _x and SO ₂ and associated monitoring requirements.
WAC 463-78-100	Registration	No	The latest version of EFSECs registration regulations in WAC 463-78-100 (effective 8/26/2019) exempts air operating permit sources from EFSECs registration program.
WAC 173-	Requirements for	No	GHEC is not located in a

Citation	Description	Applicable Requirement under Title V?	Basis
400-112	Sources in Nonattainment Areas		nonattainment area for any criteria pollutant. Therefore, this regulation is not applicable facility-wide.
WAC 173-400-120	Bubble Rules	No	GHEC has not requested an emission bubble for any regulated pollutant. Therefore, this regulation is not applicable.
WAC 173-400-131	Issuance of Emission Reduction Credits	No	GHEC has not sought emission reduction credits (ERCs). Therefore, this regulation is not applicable.
WAC 173-400-136	Use of Emission Reduction Credits	No	GHEC has not sought to use ERCs. Therefore, this regulation is not applicable.
40 CFR Part 63.6080 et seq. Subpart YYYY	National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines	No	Subpart YYYY applies to combustion turbines built after January 14, 2003 and located at major sources of HAP emissions. GHEC is facility is not a major source of HAP emissions. Therefore, Subpart YYYY does not apply.
40 CFR Part 64	Compliance Assurance Monitoring	No	<p>For NO_x, CO, Ammonia and opacity emissions, 40 CFR 64.2(b)(iv) provides an exemption from the requirements of Part 64 when a CEMS is otherwise required.</p> <p>Compliance Assurance Monitoring rule requirements do not apply to particulate, SO₂, and H₂SO₄ emissions per 40 CFR 64.2(a)(2), which includes an applicability criterion that the unit uses a control device to achieve compliance. A “control device” as defined in 40 CFR Part 64 does not include passive control measures that act to prevent pollutants from forming, such as the use low-polluting fuel or feedstocks. Because no control device is used to control</p>

Citation	Description	Applicable Requirement under Title V?	Basis
			particulate, SO ₂ or H ₂ SO ₄ , this rule does not apply to those pollutants.
40 CFR Part 98	Federal Greenhouse Gas Reporting Requirements	No	<p>The EPA greenhouse gas reporting rule was finalized September 22, 2009. In the preamble EPA responds to a question regarding whether it is an applicable requirement for the purposes of Title V:</p> <p><i>As currently written, the definition of "applicable requirement" in 40 CFR 70.2 and 71.2 does not include a monitoring rule such as today's action, which is promulgated under CAA sections 114(a)(1) and 208.</i></p> <p>Therefore, these requirements will be enforced directly by the USEPA outside of the Title V AOP program.</p>
40 CFR 63.11193 et seq. Subpart JJJJJ	National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers - Area Sources	No	<p>GHEC operates the following three steam generating units (boilers): CGT1 Heat Recovery Steam Generator (HRSG), CGT2 HRSG, and the Auxiliary Boiler. Both HRSGs are preceded by duct burners. All three units combust only natural gas and, therefore, are not subject to this regulation.</p>
40 CFR Part 60 Subpart TTTT		No	<p>In conjunction with the PSD Amendment 5 regulatory review, Ecology concluded that that the upgrade triggering PSD Amendment 5 (the AGP) would increase CO₂ emissions by approximately 9.1 percent, which is less than the applicability threshold in 40 CFR 60.5509(b)(7) of 10 percent or less (rounded to two significant figures).</p> <p>Ecology further concluded that, to assure the 10 percent CO₂</p>

Citation	Description	Applicable Requirement under Title V?	Basis
			threshold is not crossed, “EFSEC will monitor to confirm that the project will not trigger NSPS Subpart TTTT.” To enable this monitoring, an additional monitoring condition, M14, was added to the permit requiring ongoing CO ₂ monitoring and confirmation.
40 CFR Part 63 Subpart YYYY	National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines	No	This facility is not a major source of HAP emissions; therefore this regulation is not applicable to the combustion turbines at this facility.
Chapter 463-80 WAC	Carbon Dioxide Mitigation under the Carbon Dioxide Mitigation Program for Thermal Electric Generating Facilities	No.	Chapter 463-80 WAC is not pursuant to either the FCAA or Washington Clean Air Act (WCAA). Therefore, by definition, it is not an “Applicable Requirement” under Title V. GHEC is subject to a CO ₂ mitigation plan, which was required by EFSEC as a part of an amendment of the site certification agreement and EFSEC Resolution 298. However, the CO ₂ mitigation plan does not qualify as an “Applicable Requirement” under Title V.
Chapter 463-85 WAC	Greenhouse Gas Emissions Performance Standard and Sequestration Plans and Programs for Baseload Electric Generating Facilities	No	Chapter 463-85 WAC is not pursuant to either the FCAA or WCAA. Therefore, by definition, it is not an “Applicable Requirement” under Title V.
40 CFR Part 60 Subpart IIII	Standards of Performance for Stationary Compression Ignition Internal Combustion	No	The “order date” for both the Emergency Generator and Fire Water Pump precede the effective date of Subpart IIII.

Citation	Description	Applicable Requirement under Title V?	Basis
	Engines		
40 CFR Part 63 Subpart ZZZZ	National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	Yes	Applies to both Emergency Generator and Fire Water Pump.

6. Basis for AOP Terms and Conditions

Energy facilities under the jurisdiction of EFSEC are subject to EFSEC's rules under Chapter 463-78 WAC (EFSEC's Rules). Therefore, the underlying regulatory basis for all conditions in GHEC's AOP comes from EFSEC's Rules. However, because EFSEC's Rules adopt by reference (ABR) relevant state and federal rules which apply to energy facilities, the pertinent details of applicable requirements reside within the adopted rules and regulations themselves. Table 14 provides a mapping of relevant state and federal regulations that have been ABR by EFSEC.

6.1 Table 14: EFSEC Rules Adopted by Reference

Title of Rule Adopted by Reference	Citation	Citation of EFSEC Adopting Rule
Washington Air Operating Permit Regulation	Chapter 173-401 WAC	WAC 463-78-005(2)
Washington's General Regulations for Air Pollution Sources except for Ecology specific sections and adoption of federal New Source Performance Standards	Chapter 173-400 WAC	WAC 463-78-005(2)
Washington's Acid Rain Program	Chapter 173-406	WAC 463-78-005(4)
Washington's Controls for New Sources of Toxic Air Pollutants	Chapter 173-460 WAC	WAC 463-78-005(5);
Federal New Source Performance Standards	40 CFR Part 60	WAC 463-78-115;
National Emission Standards for Hazardous Air Pollutants	40 CFR Part 61	WAC 463-78-005(1)
National Emission Standards for Hazardous Air Pollutants for Source Categories	40 CFR Part 63	WAC 463-78-005(1)

In order to avoid compounding already long strings of regulatory citations in GHEC's AOP, and because pertinent details of applicable requirements reside within the ABR regulations themselves, the ABR regulations are cited in GHEC's AOP without citing the corresponding Chapter 463-78 WAC section that adopts them. Therefore, the following sections discuss the regulatory basis for AOP conditions from the standpoint of state and federal regulations that have been ABR by EFSEC.

Per the Washington Air Operating Permit Program under WAC 173-401-600, the regulatory origin and authority for each condition must be stated in an AOP. For GHEC's AOP, origin and authority are stated at the end of each permit condition. The "origin" cites the state or federal regulation or PSD/NSR permit where the applicable requirement came from. The "authority" cites the specific section in WAC 173-401 providing authority to include the requirement.

The following authorities from the Washington AOP program were used in GHEC's AOP:

6.2 Table 15: Required Permit Content, Washington AOP Program

WAC 173-401 Section:	Provides authority to include in AOP:
WAC 173-401-600(1)(a)	Federal emissions limits and standards.
WAC 173-401-600(1)(b)	State emissions limits and standards.
WAC 173-401-600(1)(c)	Requirements from permits issued by a local air pollution control authority (NOC and PSD permits).
WAC 173-401-615(1)(a)	Monitoring required by an applicable requirement.
WAC 173-401-615(1)(b)	Periodic monitoring where the applicable requirement does not require specific monitoring (commonly referred to as “gap-filling monitoring”).
WAC 173-401-615(1)(c)	As necessary, requirements concerning the use, maintenance, and, where appropriate, installation of monitoring equipment or methods.
WAC 173-401-615(2)	All applicable recordkeeping requirements and require, where applicable: <ul style="list-style-type: none"> • Records of required monitoring; • Records of changes made at the facility that result in emissions of a regulated air pollutant, but not otherwise regulated under the permit; • Retention of records of all required monitoring data and support information for a period of five years from the date the record originated; and, • Monitoring support information including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation; and, • Copies of all reports required by the permit.
WAC 173-401-615(3)	All applicable reporting requirements and require: <ul style="list-style-type: none"> • Submittal of reports of any required monitoring at least once every six months; and, • Prompt reporting of deviations from permit requirements, including those attributable to upset conditions.
WAC 173-401-620(2)	Standard Title V provisions from WAC 173-401-620(2).
WAC 173-401-605(1)	Emission limitations and standards, including those operational requirements and limitations that assure compliance with all applicable requirements at the time of permit issuance.
WAC 173-401-630(1)	Additional requirements for monitoring or monitoring equipment when monitoring is required by an applicable requirement, but it is not sufficient to assure compliance. This category of monitoring is referred to by EPA as “Sufficiency Monitoring.”
WAC 173-401-640(1)	Upon request, the permitting authority shall include in the permit or in a separate written finding issued with the permit a determination identifying specific requirements that do not apply to the source.

6.3 Permit Administration (P1–P19)

Permit administrative conditions (conditions P1–P19) include conditions specifying how the AOP is managed according to the State AOP program under Chapter 173-401 WAC and conditions having implications on assuring compliance with all other conditions in the AOP. Many of the permit administrative conditions are “standard terms and conditions” and required to be in the AOP per either Chapter 173-401 WAC or per federal requirements for AOPs.

The origin of each permit administrative condition is stated at the end of each condition. Authority to include permit administrative conditions comes primarily from WAC 173-401-600(1)(b), which specifies AOPs contain requirements from the Washington Clean Air Act (Chapter 70.94 RCW) and rules implementing that chapter (Washington’s AOP program is pursuant to RCW 70.94.162, which under the Washington Clean Air Act.).

Permit administrative conditions specify terms of the AOP such as the permit duration, expiration, renewal and revision requirements. They also explain the “Permit Shield,” extent of AOP enforceability and how the AOP can be revoked or re-opened for cause. They are essential to the proper functioning of the AOP under the State of Washington Program. Because permit administrative conditions do not include any applicable emissions limitations or operational standards, monitoring is not applicable. However, general recordkeeping and reporting requirements apply. Also, compliance with permit administrative conditions must be certified annually.

Permit Duration (condition P1)

This condition simply states the fixed term of the permit from the date of issuance is 5 years. It is important to point out that permit amendments and modifications midway during the permit term do not reestablish the permit term.

Federally Enforceable Requirements (condition P2)

Condition P2 distinguishes between AOP conditions containing federally enforceable requirements from those that are not federally enforceable.

Requirements that only the Ecology has authority to enforce are designated as “State only.” Although EFSEC may enforce the specific provisions of the AOP permit condition containing a “State only” requirement, only Ecology may enforce the underlying rule, regulation, or standard that imposes the requirement. The best example is the State’s rules for reporting greenhouse gas emissions titled, Reporting of Emissions of Greenhouse Gases, under Chapter 173-441 WAC. The “core” requirements from Chapter 173-441 WAC to monitor, record, and report greenhouse gas emissions are included as conditions in GHEC’s AOP and may be enforced by EFSEC. However, only Ecology may directly enforce the rule itself.

AOP conditions containing requirements that are not federally enforceable but are directly enforceable by both Ecology and EFSEC are identified as “State/EFSEC only.” In general, these include State air regulations that have no implications on achieving or maintaining the National Ambient Air Quality Standards. Examples include the State’s nuisance odor

prohibitions and the standards for toxic air pollutant emissions. These are enforceable by Ecology and EFSEC but are not federally enforceable.

AOP conditions containing requirements that are federally enforceable and enforceable by EFSEC and Ecology do not include “State only” or “State/EFSEC” in the permit condition basis statement at the end of the condition.

Compliance Maintenance (condition P3)

This condition contains the requirement that the Permittee must maintain compliance with all applicable requirements in the AOP and those that become effective during the permit term.

Standard Conditions (condition P4)

Both the origin and authority to include this condition come from WAC 173-401-620(2). The condition identifies general duty and administrative requirements that are standard for all AOPs including the duty to comply and duty to provide information.

AOP Administration Conditions (conditions P5-P14)

Conditions P4 through P14 contain requirements for AOP permit administration from the State’s Air Operating Permit regulation like permit renewal requirements, permit modifications, administrative amendments, duty to supplement or correct an application. These are all considered standard terms of the permit

Greenhouse Gas Reporting Fee (condition P15)

Condition P15 contains the requirement from WAC 173-441-110 that a Greenhouse Gas (GHG) reporting fee be paid to Ecology each year and a GHG report to Ecology is required. This requirement is not federally enforceable and is a “State only” requirement.

Confidential Information (condition P16)

The origins of this condition are WAC 173-401-500(5) and WAC 173-401-620(2)(e). The condition identifies the essential standards for considering and handling confidential information. Justification for its inclusion in the AOP is that it establishes the standard for handling confidential information under Title V. Authority to include the condition in the permit comes from WAC 173-401-600(1)(b).

Credible Evidence (condition P17)

Condition P17 contains important provisions from the Credible Evidence Rule under 40 CFR Part 51, and from provisions under 40 CFR Part 60 and 61 concerning credible evidence. In general, these rules provide that the permittee may use any credible evidence outside of the monitoring and testing required by the AOP to support a compliance determination. The authority to include this condition is WAC 173-401-600(1)(a), which requires AOPs contain terms and conditions that assure compliance with all applicable federal requirements. There may be times when the permittee must augment the monitoring and testing required

by the AOP with other information in order to demonstrate or assure continuous compliance. This condition allows for the use of credible evidence.

Unavoidable Excess Emissions (condition P18)

Condition P18 contains requirements from WAC 173-400-108 governing treatment of unavoidable excess emissions, which are included in the current Washington State Implementation Plan (SIP). The SIP is comprised of rules, which the State of Washington has adopted, and EPA has approved, for maintaining the National Ambient Air Quality Standards. The current SIP was adopted by EPA September 20, 1993.

Certification (condition P19)

In accordance with WAC 173-401-520, all application forms, reports, and compliance certifications must be certified for truth and accuracy by a responsible official. Therefore, this requirement has implications all other requirements in the AOP requiring compliance reports to EFSEC. The requirement to certify reports for truth and accuracy is considered an applicable requirement. It is included in the AOP under the general authority provided by WAC 173-401-600(1)(b), which requires permits contain terms and conditions sufficient to assure compliance with all applicable requirements under the WCAA.

6.4 General Terms and Conditions (G1 – G16)

General terms and conditions (G1 – G16) cover general compliance and permitting requirements including:

- Access for inspection of GHEC;
- Treatment of insignificant emissions units;
- Pre-construction permitting requirements;
- Temporary source requirements;
- Asbestos and demolition permitting;
- Chemical Accident Prevention Program;
- Stratospheric Ozone Protection Program;
- Outdoor burning requirements;
- General emissions testing requirements; and,
- Acid Rain Program.

These conditions are categorized as General Terms and Conditions in GHEC's AOP because they either have broad implications on multiple conditions in the AOP, or are entire programs that are applicable if triggered, such as the Stratospheric Ozone Protection program. Authority for each condition varies depending on whether the applicable requirement originated from a state or federal regulation.

Inspection and Entry (condition G1)

Condition G1 contains requirements for inspection and entry to the facility. The specific provisions and requirements governing inspection and entry originate from WAC 173-401-630(2) and WAC 173-400-105(3)8(4). Authority to include these requirements in the AOP comes from WAC 173-401-600(1)(b).

Insignificant Emission Units (condition G2)

Condition G2 contains specific Title V requirements for insignificant emissions units determined insignificant based on actual emissions in accordance with WAC 173-401-530(1)(a).

New Source Review Requirements (conditions G3 & G4)

Conditions G3 & G4 reference the procedural requirements for securing EFSEC's approval prior to commencing any project triggering an air permit from EFSEC. These requirements include requirements for NOC, PSD, and modifications, and are generally referred to as "New Source Review." They become applicable when triggered and must be complied with prior to commencing any project triggering an air permit through EFSEC. Authority to include the requirements in GHEC's AOP comes from the general authority provided by WAC 173-401-600(1)(b).

Temporary Source provisions (condition G5)

Condition G5 contains EFSEC's requirements for temporary, portable sources that remain no longer than one year at the facility.

Asbestos, Demolition and Renovation Projects (condition G6)

Condition G6 identifies 40 CFR Part 61, Subpart M as the applicable regulation for asbestos, demolition, and renovation projects.

Chemical Accident Prevention (condition G7)

Chemical accident prevention under the federal Risk Management Plan (RMP) program (40 CFR Part 68) applies to any industrial facility that uses or stores any extremely hazardous substance. The RMP program requires subject facilities to develop an RMP for all substances used above a threshold quantity.

GHE does use and store aqueous ammonia, which is a chemical regulated under the RMP program. The RMP program applies to facilities that use or store 20,000 pounds of aqueous ammonia (conc 20% or greater) during any year. GHEC's use of aqueous ammonia has been below this threshold concentration since the facility began operation. However, because there is a potential for aqueous ammonia to be used above the RMP rule threshold quantity, condition G7 was added to GHEC's AOP. The specific requirements of the RMP rule remain dormant unless a regulated substance is used above its threshold quantity.

The RMP program is considered an applicable federal regulatory program. Therefore, authority to include condition G8 comes from WAC 173-401-600(1)(a), which requires permits contain terms and conditions sufficient to assure compliance with all applicable federal emissions limits and standards. Although it is unlikely GHEC will trigger the RMP program, the program must be acknowledged in the AOP as applicable if triggered.

Protection of Stratospheric Ozone (condition G8)

Incorporates by reference the federal requirements for protection of stratospheric ozone from 40 CFR Part 82, Subpart F. Because EFSEC has not adopted by reference these standards and had not requested delegation to enforce them, they are not directly enforceable by EFSEC. However, they are required to be in all Title V permits and EFSEC is responsible for verifying compliance with the requirements is both assured and monitored by GHE.

Outdoor Burning (condition G9)

Outdoor burning is generally prohibited but may be permitted as allowed by WAC 173-425. However unlikely for GHEC, the requirement was included in the AOP to allow for permitted outdoor burning. Authority to include it in the AOP comes from the general authority provided by WAC 173-401-600(1)(b). Any permit allowing outdoor burning would be issued by EFSEC's contractor, ORCAA.

Concealment and Masking Prohibited (condition G10)

This condition contains the state-wide requirement that prohibits concealing an air emission that would otherwise cause a violation of an applicable standard, such as use of gaseous diluents to achieve compliance a standard.

Circumvention (condition G11)

This condition contains the federal requirement that prohibits concealing an air emission that would otherwise cause a violation of an applicable standard, such as use of gaseous diluents to achieve compliance a standard.

General Emissions Testing Requirement (condition G12)

This condition states EFSEC's general authority to require testing.

Acid Rain Program – Duty to reapply (condition G13)

Condition G13 states the requirement that an acid rain permit renewal application must be submitted along with the AOP renewal application. GHEC submitted the requisite acid rain permit application. Both permits expire on <permit expiration date>. Renewal applications for each are due to EFSEC no later than <permit renewal application due date>.

Acid Rain Program – Designated Representative (condition G14)

This condition contains the definition of the "Designated representative" as required under the State's Acid Rain Program.

Reporting to Verify PSD Applicability Determinations (condition G15)

This condition was recommended by the Ecology to satisfy the monitoring, recordkeeping and reporting needed to assure ongoing relevance of PSD applicability determinations.

Prevention of Significant Deterioration (PSD) (condition G16)

This condition includes EFSECs PSD and major New Source Review requirements and applies for projects triggering PSD.

6.5 Applicable Requirements

Applicable requirements (AR1 – AR5) cover applicable emissions limits and operating standards from applicable state and federal regulations and NOC and PSD permits issued by EFSEC to GHEC. Origin and authority are stated at the end of each condition. All monitoring and recordkeeping details are included in the Monitoring section of the AOP.

Applicable requirements are divided into the following subcategories:

- General facility-wide standards and prohibitions primarily from Chapter 173-400 WAC;
- NSPS for gas turbines and duct burners from 40 CFR 60 Subpart KKK;
- PSD Amendment 5 permit requirements for the CGTs;
- PSD Amendment 5 permit requirements for the Auxiliary Boiler;
- PSD Amendment 5 permit requirements for the emergency diesel engines; and,
- PSD and NOC permit requirements for the Cooling Tower.

NSPS General Duty Requirements (condition AR1.1)

This condition contains the general “blanket” requirement that emissions units subject to NSPS be operated in a manner consistent with good air pollution control practice for minimizing emissions. It is a requirement from the general NSPS requirements under 40 CFR60.11(d) and applies to all emissions units subject to a federal NSPS. For GHEC, the CGTs, Duct Burners, Auxiliary Boiler and Emergency Engines are all subject to federal NSPS and, therefore must abide by this general requirement.

Washington General Standards (condition AR1.2 – 1.10)

Conditions AR1.2 – AR1.10 contain applicable requirements from the States General Regulations for Air Pollution Sources under Chapter 173-400 WAC. These requirements apply plant-wide to all emissions units including insignificant emissions units (IEUs). However, IEUs are not subject to the monitoring, recordkeeping and reporting requirements of the AOP.

Acid Rain Program (condition AR1.11)

Condition AR1.11 contains the plant-wide SO₂ allowance requirement from GHEC’s Acid Rain Program permit. This is the primary requirement from the Acid Rain Program permit.

Required Plans (condition AR1.12)

Condition AR1.12 requires the permittee develop, maintain, and follow:

- An Operating and Maintenance manual (O&M Manual); and,
- An equipment Start-up, Shutdown, and Malfunction Procedures manual (SSM Manual).

Both manuals are required to describe accepted operating procedures for minimizing emissions from all emissions units at the facility. The origin of this requirement is PSD Amendment 5.

NSPS for Stationary Gas Turbines (conditions AR2.1 – AR2.2)

Conditions AR2.1 – AR2.2 contain applicable requirements from the federal Standards of Performance for Stationary Gas Turbines under CFR 60 Subpart KKKK (Subpart KKKK). Subpart KKKK applies to stationary gas turbines with a heat input at peak load equal to or greater than 10 million Btu per hour (MMBtu/hr), based on the lower heating value of the fuel fired. Because both turbines at GHEC have heat input rates well above this threshold, and because they were modified after the effective date of the regulation (February 18, 2005), Subpart KKKK applies.

Subpart KKKK imposes both NO_x and SO₂ standards for stationary gas turbines that apply at all times including startup, shutdown, and malfunction events.

The Subpart KKKK standard for NO_x is based on the standard stated for turbines firing natural gas and with heat rates greater than 850 MMBtu/hr, which is provided in Table 1 of the regulation:

NO_x standard for new, modified, or reconstructed turbine firing natural gas > 850 MMBtu/h:

15 ppm at 15 percent O₂ or 54 ng/J of useful output (0.43 lb/MWh)

NO_x standard for heat recovery units operating independent of the combustion turbine:

54 ppm at 15 percent O₂ or 110 ng/J of useful output (0.86 lb/MWh)

The Subpart KKKK NO_x standards are included in condition AR 2.1. Subpart KKKK requirements for the NO_x-diluent CEMS incorporate by reference the monitoring requirements from 40 CFR Part 75.

The Subpart KKKK standard for SO₂ for natural gas fired turbines is:

You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO₂/J (0.060 lb SO₂/MMBtu) heat input

The SO₂ standard from Subpart KKKK is included as a limit in condition AR2.2. Required monitoring is based on sulfur mass balance calculations as specified in conditions M8, M9, and M12, which rely on fuel combustion monitoring and periodically measuring the heat and sulfur content of the natural gas per methods and protocols from 40 CFR Part 75.

PSD Requirements for CGTs (conditions AR2.3 – AR2.17)

Conditions AR2.3 – AR2.17 include applicable requirements from PSD Amendment 5 (PSD permit) applying to the CGTs. All requirements are in equivalent to the conditions as written in the PSD permit except for some reorganization and adding clarification of requirements for continuous emissions monitoring systems (CEMS) and continuous monitoring systems (CMS).

Clarification of requirements for CEMS and CMS was necessary for two reasons:

1. The CGTs are subject to multiple standards for the same pollutant from different regulations, each which have their own unique CEMS and CMS requirements. As a result, there are redundancies in CEMS and CMS requirements and some apparent conflicting requirements that needed to be resolved and harmonized in the AOP.
2. The PSD permit incorporates by reference federal performance standards and quality assurance procedures for CEMS and CMS, which are general and cover all possible scenarios and fuel types for affected facilities. As a result, requirements applying specifically to GHEC are difficult to identify due to the sheer volume of inapplicable provisions within the referenced federal standards. For example, the adopted requirements for NO_x monitoring under 40 CFR Part 75 spans well over 300 pages of CFR and itself references several other equally extensive sections of the CFR.

Because of this, requirements for CEMS and CMS in general rely heavily on adopting the federal requirements by reference in the permit.

PSD Requirements for the Auxiliary Boiler (conditions AR3.1 – AR3.8)

Conditions AR3.1 – AR3.8 include applicable requirements from PSD Amendment 5 (PSD permit) applying to the Auxiliary Boiler. All requirements are in equivalent to the conditions as written in the PSD permit except for some reorganization and adding clarification of requirements for monitoring.

Requirements for Emergency Diesel Engines (conditions AR4.1 – AR4.6)

Conditions AR4.1 – AR4.6 include applicable federal requirements and requirements from PSD Amendment 5 (PSD permit) applying to diesel fired emergency engines at the facility.

PSD and NOC Requirements for Cooling Towers (conditions AR5.1 – AR5.2)

Conditions AR5.1 – AR5.2 include applicable requirements from the NOC approving upgrades to GHEC's cooling towers as well as applicable PSD permit conditions.

6.6 Monitoring and Recordkeeping Conditions

Applicable monitoring and recordkeeping conditions (M1 – M13) include all required monitoring from applicable federal subparts and the PSD permit, and additional monitoring determined necessary to assure sufficient monitoring meeting title V requirements. Origin and authority are stated at the end of each condition. Regulatory origins are stated at the end of each condition.

6.7 General Recordkeeping Requirements

Applicable recordkeeping requirements were aggregated with monitoring conditions in the permit.

6.8 Reporting

Applicable reporting terms and conditions (R1–R11) include all required reporting requirements for Title V AOPs as required under WAC 173-401-615(32). Origin and authority are stated at the end of each condition.

6.9 Permit Shield

WAC 173-401-640 under Washington’s Operating Permit regulations requires AOPs to include a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit. This provision is referred to as the “Permit Shield.” Sub-section (2) of WAC 173-401-640 clarifies the effect of the Permit Shield on requirements determined inapplicable, and requires the permitting authority to include in the permit or in a separate written finding issued with the permit, a determination identifying specific requirements that do not apply to the source.

Conditions S1-S3 in GHEC’s AOP provides the “Permit Shield” and list relevant requirements determined inapplicable.

7. Environmental Justice

EPA defines Environmental Justice (EJ) as the fair treatment and meaningful involvement of all people regardless of race, color, national origin, or income, with respect to the development, implementation, and enforcement of environmental laws, regulations, and policies. The purpose of an EJ review in conjunction with a Title V permitting action is to ensure no group of people are bearing a disproportionate share of any negative environmental consequences from the facility subject to the Title V permitting action. Further, EFSEC strives to engage the affected community meaningfully and effectively regarding the permitting action, and to ensure compliance with obligations pursuant to Title VI of the Civil Rights Act.

With respect to integrating EJ into air permitting decisions, EPA Region 10 expects air agencies including EFSEC to:

- Identify overburdened communities;
- Engage with communities;
- Evaluate cumulative impacts; and,
- Use available authority to minimize emissions.

However, EPA Region 10 does not expect air agencies or EFSEC to use the Clean Air Act’s authorities to address disproportional impacts to communities that are designated as “attainment/unclassifiable” with respect to meeting the National Ambient Air Quality

Standard (NAAQS).

A designation is a label that EPA assigns to an area to describe the air quality for any of six common air pollutants for which EPA has established a NAAQS. These pollutants are called “criteria pollutants.” If the air quality in a geographic area meets or is cleaner than the national standard, it is called an attainment area and designated “attainment/unclassifiable.” Areas that don't meet the national standard are called nonattainment areas. In some cases, EPA is not able to determine an area's status after evaluating the available information and those areas are designated “unclassifiable.” GHEC is located within Grays Harbor County, which is designated “attainment/unclassifiable” for all the criteria air pollutants.

The following subsections describe how EPA's expectations for EJ were met for this Title V permitting action.

7.1 Identify Overburdened Communities

The initial step in an EJ review is to identify any affected populations or communities of concern and to identify whether they are disproportionately impacted.

EPA's environmental justice screening and mapping tool, EJ Screen, was used to answer the first part of this question. An EJ Screen Community Report was generated for Grays Harbor County. The Community Report estimates a minority population of 22%, with approximately 7% of the total population speaking Spanish and 2% speaking another non-English language at home. All demographic indicators were below the 80th percentile for the nation.

The Community Report also ranks the community with respect to environmental indicators such as toxic releases to the air, traffic, hazardous waste discharges, and others. The 80th nation-wide percentile for any environmental indicator is used as a threshold to identify communities may already be disproportionately impacted. Grays Harbor County ranks below the 80th nation-wide percentile for all environmental indicators. Therefore, based on EJ Screen, the area surrounding GHEC does not include any preexisting, overburdened communities. A copy of the Community Report with more detailed information will be filed as part of the supporting documentation for this Title V permitting action.

7.2 Engage with Communities

EFSEC's policy is to engage the public through a public comment period on the draft AOP. EFSEC's current public notice and outreach policies and procedures are sufficient to effectively provide notice of the hearing and meaningfully engage with the community. Public noticing actions that will be taken by EFSEC for this AOP modification include:

- Publishing the Public Notice and Draft AOP on EFSEC's web site.
- Noticing the action through the Washington State Permit Register.
- Providing notice via email or mail to “Affected States” within 50 miles of the GHEC.
- Providing notice via email or mail to interested persons and entities.

After the public comment period, and hearing if one is held, and after considering all

comments submitted, EFSEC will prepare a written Responsiveness Summary. The Responsiveness summary will include a description of EFSEC's Final Decision as well as responses to questions and comments received during the comment period and public hearing. EFSEC's Responsiveness Summary will be forwarded to all persons and entities who submitted comments during the comment period and public hearing.

7.3 Evaluate Cumulative Impacts

EJ policies require that cumulative impacts be identified and addressed in any permit decision. However, as mentioned previously, EPA does not expect air agencies or EFSEC to use Clean Air Act authorities to address any disproportionate impacts to communities that are designated as "attainment/unclassifiable" with respect to the NAAQS. Therefore, a cumulative impacts evaluation was not performed for this Title V permitting action because:

1. Grays Harbor County is designated "attainment/unclassifiable" with respect to all criteria air pollutants;
2. Title V permitting actions do not require an evaluation of ambient air quality impacts; and,
3. EJ Screen results did not indicate any preexisting, overburdened communities.

7.4 Use Available Authority to Minimize Emissions

The purpose of Title V permitting actions is to assimilate all applicable air requirements for existing air pollution sources at a facility that is a "Major Source," into a single permit that must be renewed every five years. Title V does not provide authority to impose additional air pollution control requirements or limits, except for monitoring. Therefore, because the permitting action was a Title V permitting action, EFSEC did not have authority to minimize emissions by imposing new limits or requirements. However, GHEC did impose additional monitoring requirements for emissions limits that do not specify any monitoring, or when the applicable monitoring requirements were determined insufficient to assure compliance.